



**Greenlink Analytical and Research
Laboratory (India) Private Ltd.**

S.F. No. 414/1, Tex Park Road, Opp. Good Luck Syndicate,
Civil Aerodrome Post, Coimbatore - 641 014, Tamilnadu, INDIA.

Tel : +91 422 2901999 | Mob : +91 95245 81999, +91 95249 81999

Email : enquiry@greenlinklabs.com, info@greenlink.in

NABL
ISO / IEC 17025
Accredited

ISO
9001 : 2015
Certified

TEST REPORT

Report No.		GLARL/TRE/0394	Date	21.06.2022		
Details of Customer						
Customer Name and Address		Keystone Foundation Groves Hills Roads, BB 35, Kotagiri, Nilgiris – 643 217.				
Customer Reference						
Details of Sample						
Sample Received Date	17.06.2022		Sample-By	Greenlink		
Nature of Sample	Water-Sample 1		Description	Colorless, clear, transparent liquid.		
Sample Code	GLARL/WA/06/22/0394		Received Condition	Packed in a HDP can		
Analysis Started on	18.06.2022		Analysis Completed on	21.06.2022		
Result of Analysis						
S. No	Characteristic	Test Method		Unit	Result	Standard
1.	Colour	Standard. Methods 23 rd Ed.2120 B		Hazen	<1.0	5.0
2.	Odour	Standard. Methods 23 rd Ed.2150 B		-	Agreeable	Agreeable
3.	Taste	Standard. Methods 23 rd Ed.2160 B		-	Agreeable	Agreeable
4.	pH @ 25°C	Standard. Methods 23 rd Ed.4500 H ⁺ B		-	5.67	6.5-8.5
5.	Electrical Conductivity@ 25°C	Standard. Methods 23 rd Ed.2510 B		µS/cm	720	-
6.	Total Dissolved Solids	Standard. Methods 23 rd Ed.2540 C		mg/L	440	500
7.	Turbidity	Standard. Methods 23 rd Ed.2130 B		NTU	0.13	1.0
8.	Total Hardness (as CaCO ₃)	Standard. Methods 23 rd Ed.2340 C		mg/L	150	200
9.	Calcium (as Ca)	Standard. Methods 23 rd Ed.3500 Ca B		mg/L	40	75
10.	Magnesium (as Mg)	Standard. Methods 23 rd Ed.3500 Mg B		mg/L	12.6	30
11.	Total Alkalinity (as CaCO ₃)	Standard. Methods 23 rd Ed.2320 B		mg/L	38	200
12.	Chlorides (as Cl)	Standard. Methods 23 rd Ed.4500 Cl B		mg/L	124	250
13.	Sulphate (as SO ₄)	Standard. Methods 23 rd Ed.4500 SO ₄ E		mg/L	11.7	250

Cont.....

TEST REPORT

Report No.	GLARL/TRE/0394	Date	21.06.2022
-------------------	----------------	-------------	------------

Result of Analysis					
S. No	Characteristic	Test Method	Unit	Result	Standard
14.	Silica (as SiO ₂)	Standard. Methods 23 rd Ed.4500 SiO ₂ -C	mg/L	0.773	-
15.	Total Iron (as Fe)	Standard. Methods 23 rd Ed.3500 Fe B	mg/L	0.026	0.3
16.	Nitrate (as NO ₃)	Standard. Methods 23 rd Ed.4500 NO ₂ B	mg/L	42.4	45
17.	Fluoride (as F)	Standard. Methods 23 rd Ed.4500 F-D	mg/L	0.842	1.0
18.	Total Residual Chlorine	Standard. Methods 23 rd Ed.4500 Cl(R)B	mg/L	BDL (DL:0.1)	0.2
19.	Aluminium	Standard. Methods 23 rd Ed. 3500 Al B	mg/L	BDL (DL:0.01)	0.03
20.	Ammonia	Standard. Methods 23 rd Ed.4500 NH ₃ B, C	mg/L	BDL (DL:0.1)	0.5
21.	Anionic Detergents	Standard. Methods 23 rd Ed.5540	mg/L	BDL (DL:0.01)	0.2
22.	Sodium (as Na)	Standard. Methods 23 rd Ed.3500 Na B	mg/L	100	-
23.	Potassium (as K)	Standard. Methods 23 rd Ed.3500 K B	mg/L	20.9	-
24.	Coliform	IS 15185:2002	MPN/ 100ml	<1.8	Absent
25.	<i>Escherichia coli</i>	IS 15185:2002	-	Absent	Absent

BDL- Below Detectable Level

DL-Detectable Level

...End of Report...



M. Amsaveni

Authorized Signatory

(M.Amsaveni)

Technical Manager



**Greenlink Analytical and Research
Laboratory (India) Private Ltd.**

S.F. No. 414/1, Tex Park Road, Opp. Good Luck Syndicate,
Civil Aerodrome Post, Coimbatore - 641 014. Tamilnadu, INDIA.

Tel : +91 422 2901999 | Mob : +91 95245 81999, +91 95249 81999

Email : enquiry@greenlinklabs.com, info@greenlink.in



TEST REPORT

Report No.		GLARL/TRE/0395	Date	21.06.2022		
Details of Customer						
Customer Name and Address		Keystone Foundation Groves Hills Roads, BB 35, Kotagiri, Nilgiris – 643 217.				
Customer Reference						
Details of Sample						
Sample Received Date	17.06.2022		Sample-By	Greenlink		
Nature of Sample	Water-Sample 2		Description	Colorless, clear, transparent liquid.		
Sample Code	GLARL/WA/06/22/0395		Received Condition	Packed in a HDP can		
Analysis Started on	18.06.2022		Analysis Completed on	21.06.2022		
Result of Analysis						
S. No	Characteristic	Test Method		Unit	Result	Standard
1.	Colour	Standard. Methods 23 rd Ed.2120 B		Hazen	<1.0	5.0
2.	Odour	Standard. Methods 23 rd Ed.2150 B		-	Agreeable	Agreeable
3.	Taste	Standard. Methods 23 rd Ed.2160 B		-	Agreeable	Agreeable
4.	pH @ 25°C	Standard. Methods 23 rd Ed.4500 H ⁺ B		-	5.48	6.5-8.5
5.	Electrical Conductivity@ 25°C	Standard. Methods 23 rd Ed.2510 B		µS/cm	310	-
6.	Total Dissolved Solids	Standard. Methods 23 rd Ed.2540 C		mg/L	190	500
7.	Turbidity	Standard. Methods 23 rd Ed.2130 B		NTU	0.16	1.0
8.	Total Hardness (as CaCO ₃)	Standard. Methods 23 rd Ed.2340 C		mg/L	70.5	200
9.	Calcium (as Ca)	Standard. Methods 23 rd Ed.3500 Ca B		mg/L	15.1	75
10.	Magnesium (as Mg)	Standard. Methods 23 rd Ed.3500 Mg B		mg/L	8.0	30
11.	Total Alkalinity (as CaCO ₃)	Standard. Methods 23 rd Ed.2320 B		mg/L	22	200
12.	Chlorides (as Cl)	Standard. Methods 23 rd Ed.4500 Cl B		mg/L	53	250
13.	Sulphate (as SO ₄)	Standard. Methods 23 rd Ed.4500 SO ₄ E		mg/L	6.83	250

Cont.....

TEST REPORT

Report No.	GLARL/TRE/0395	Date	21.06.2022
-------------------	----------------	-------------	------------

Result of Analysis					
S. No	Characteristic	Test Method	Unit	Result	Standard
14.	Silica (as SiO ₂)	Standard. Methods 23 rd Ed.4500 SiO ₂ -C	mg/L	1.347	-
15.	Total Iron (as Fe)	Standard. Methods 23 rd Ed.3500 Fe B	mg/L	0.009	0.3
16.	Nitrate (as NO ₃)	Standard. Methods 23 rd Ed.4500 NO ₂ B	mg/L	33.4	45
17.	Fluoride (as F)	Standard. Methods 23 rd Ed.4500 F-D	mg/L	0.138	1.0
18.	Total Residual Chlorine	Standard. Methods 23 rd Ed.4500 Cl(R)B	mg/L	BDL (DL:0.1)	0.2
19.	Aluminium	Standard. Methods 23 rd Ed. 3500 Al B	mg/L	BDL (DL:0.01)	0.03
20.	Ammonia	Standard. Methods 23 rd Ed.4500 NH ₃ B, C	mg/L	BDL (DL:0.1)	0.5
21.	Anionic Detergents	Standard. Methods 23 rd Ed.5540	mg/L	BDL (DL:0.01)	0.2
22.	Sodium (as Na)	Standard. Methods 23 rd Ed.3500 Na B	mg/L	36	-
23.	Potassium (as K)	Standard. Methods 23 rd Ed.3500 K B	mg/L	3.1	-
24.	Coliform	IS 15185:2002	MPN/ 100ml	<1.8	Absent
25.	<i>Escherichia coli</i>	IS 15185:2002	-	Absent	Absent

BDL- Below Detectable Level

DL-Detectable Level

...End of Report...



M. Amsaveni
Authorized Signatory
(M.Amsaveni)
Technical Manager



**Greenlink Analytical and Research
Laboratory (India) Private Ltd.**

S.F. No. 414/1, Tex Park Road, Opp. Good Luck Syndicate,
Civil Aerodrome Post, Coimbatore - 641 014. Tamilnadu, INDIA.

Tel : +91 422 2901999 | Mob : +91 95245 81999, +91 95249 81999

Email : enquiry@greenlinklabs.com, info@greenlink.in

NABL
ISO / IEC 17025
Accredited

ISO
9001 : 2015
Certified

TEST REPORT

Report No.		GLARL/TRE/0396	Date	21.06.2022	
Details of Customer					
Customer Name and Address		Keystone Foundation Groves Hills Roads, BB 35, Kotagiri, Nilgiris – 643 217.			
Customer Reference					
Details of Sample					
Sample Received Date	17.06.2022	Sample-By	Greenlink		
Nature of Sample	Water-Sample 3	Description	Colorless, clear, transparent liquid.		
Sample Code	GLARL/WA/06/22/0396	Received Condition	Packed in a HDP can		
Analysis Started on	18.06.2022	Analysis Completed on	21.06.2022		
Result of Analysis					
S. No	Characteristic	Test Method	Unit	Result	Standard
1.	Colour	Standard. Methods 23 rd Ed.2120 B	Hazen	<1.0	5.0
2.	Odour	Standard. Methods 23 rd Ed.2150 B	-	Agreeable	Agreeable
3.	Taste	Standard. Methods 23 rd Ed.2160 B	-	Agreeable	Agreeable
4.	pH @ 25°C	Standard. Methods 23 rd Ed.4500 H ⁺ B	-	5.43	6.5-8.5
5.	Electrical Conductivity@ 25°C	Standard. Methods 23 rd Ed.2510 B	µS/cm	75	-
6.	Total Dissolved Solids	Standard. Methods 23 rd Ed.2540 C	mg/L	45	500
7.	Turbidity	Standard. Methods 23 rd Ed.2130 B	NTU	0.07	1.0
8.	Total Hardness (as CaCO ₃)	Standard. Methods 23 rd Ed.2340 C	mg/L	43	200
9.	Calcium (as Ca)	Standard. Methods 23 rd Ed.3500 Ca B	mg/L	10.5	75
10.	Magnesium (as Mg)	Standard. Methods 23 rd Ed.3500 Mg B	mg/L	4.1	30
11.	Total Alkalinity (as CaCO ₃)	Standard. Methods 23 rd Ed.2320 B	mg/L	16	200
12.	Chlorides (as Cl)	Standard. Methods 23 rd Ed.4500 Cl B	mg/L	19	250
13.	Sulphate (as SO ₄)	Standard. Methods 23 rd Ed.4500 SO ₄ E	mg/L	5.02	250

Cont.....

TEST REPORT

Report No.	GLARL/TRE/0396	Date	21.06.2022
-------------------	----------------	-------------	------------

Result of Analysis					
S. No	Characteristic	Test Method	Unit	Result	Standard
14.	Silica (as SiO ₂)	Standard. Methods 23 rd Ed.4500 SiO ₂ -C	mg/L	1.913	-
15.	Total Iron (as Fe)	Standard. Methods 23 rd Ed.3500 Fe B	mg/L	0.012	0.3
16.	Nitrate (as NO ₃)	Standard. Methods 23 rd Ed.4500 NO ₂ B	mg/L	4.60	45
17.	Fluoride (as F)	Standard. Methods 23 rd Ed.4500 F-D	mg/L	0.012	1.0
18.	Total Residual Chlorine	Standard. Methods 23 rd Ed.4500 Cl(R)B	mg/L	BDL (DL:0.1)	0.2
19.	Aluminium	Standard. Methods 23 rd Ed. 3500 Al B	mg/L	BDL (DL:0.01)	0.03
20.	Ammonia	Standard. Methods 23 rd Ed.4500 NH ₃ B, C	mg/L	BDL (DL:0.1)	0.5
21.	Anionic Detergents	Standard. Methods 23 rd Ed.5540	mg/L	BDL (DL:0.01)	0.2
22.	Sodium (as Na)	Standard. Methods 23 rd Ed.3500 Na B	mg/L	7.3	-
23.	Potassium (as K)	Standard. Methods 23 rd Ed.3500 K B	mg/L	1.3	-
24.	Coliform	IS 15185:2002	MPN/ 100ml	<1.8	Absent
25.	<i>Escherichia coli</i>	IS 15185:2002	-	Absent	Absent

BDL- Below Detectable Level

DL-Detectable Level

...End of Report...



M. Amsaveni
Authorized Signatory
(M.Amsaveni)
Technical Manager



**Greenlink Analytical and Research
Laboratory (India) Private Ltd.**

S.F. No. 414/1, Tex Park Road, Opp. Good Luck Syndicate,
Civil Aerodrome Post, Coimbatore - 641 014. Tamilnadu, INDIA.

Tel : +91 422 2901999 | Mob : +91 95245 81999, +91 95249 81999

Email : enquiry@greenlinklabs.com, info@greenlink.in

NABL
ISO / IEC 17025
Accredited

ISO
9001 : 2015
Certified

TEST REPORT

Report No.	GLARL/TRE/0397	Date	21.06.2022		
Details of Customer					
Customer Name and Address	Keystone Foundation Groves Hills Roads, BB 35, Kotagiri, Nilgiris – 643 217.				
Customer Reference					
Details of Sample					
Sample Received Date	17.06.2022	Sample-By	Greenlink		
Nature of Sample	Water-Sample 4	Description	Colorless, clear, transparent liquid.		
Sample Code	GLARL/WA/06/22/0397	Received Condition	Packed in a HDP can		
Analysis Started on	18.06.2022	Analysis Completed on	21.06.2022		
Result of Analysis					
S. No	Characteristic	Test Method	Unit	Result	Standard
1.	Colour	Standard. Methods 23 rd Ed.2120 B	Hazen	<1.0	5.0
2.	Odour	Standard. Methods 23 rd Ed.2150 B	-	Agreeable	Agreeable
3.	Taste	Standard. Methods 23 rd Ed.2160 B	-	Agreeable	Agreeable
4.	pH @ 25°C	Standard. Methods 23 rd Ed.4500 H ⁺ B	-	5.36	6.5-8.5
5.	Electrical Conductivity@ 25°C	Standard. Methods 23 rd Ed.2510 B	µS/cm	145	-
6.	Total Dissolved Solids	Standard. Methods 23 rd Ed.2540 C	mg/L	89	500
7.	Turbidity	Standard. Methods 23 rd Ed.2130 B	NTU	0.12	1.0
8.	Total Hardness (as CaCO ₃)	Standard. Methods 23 rd Ed.2340 C	mg/L	37.6	200
9.	Calcium (as Ca)	Standard. Methods 23 rd Ed.3500 Ca B	mg/L	10.54	75
10.	Magnesium (as Mg)	Standard. Methods 23 rd Ed.3500 Mg B	mg/L	6.58	30
11.	Total Alkalinity (as CaCO ₃)	Standard. Methods 23 rd Ed.2320 B	mg/L	16	200
12.	Chlorides (as Cl)	Standard. Methods 23 rd Ed.4500 Cl B	mg/L	21.5	250
13.	Sulphate (as SO ₄)	Standard. Methods 23 rd Ed.4500 SO ₄ E	mg/L	6.61	250

Cont.....

TEST REPORT

Report No.	GLARL/TRE/0397	Date	21.06.2022
-------------------	----------------	-------------	------------

Result of Analysis					
S. No	Characteristic	Test Method	Unit	Result	Standard
14.	Silica (as SiO ₂)	Standard. Methods 23 rd Ed.4500 SiO ₂ -C	mg/L	1.330	-
15.	Total Iron (as Fe)	Standard. Methods 23 rd Ed.3500 Fe B	mg/L	0.011	0.3
16.	Nitrate (as NO ₃)	Standard. Methods 23 rd Ed.4500 NO ₂ B	mg/L	25	45
17.	Fluoride (as F)	Standard. Methods 23 rd Ed.4500 F-D	mg/L	0.007	1.0
18.	Total Residual Chlorine	Standard. Methods 23 rd Ed.4500 Cl(R)B	mg/L	BDL (DL:0.1)	0.2
19.	Aluminium	Standard. Methods 23 rd Ed. 3500 Al B	mg/L	BDL (DL:0.01)	0.03
20.	Ammonia	Standard. Methods 23 rd Ed.4500 NH ₃ B, C	mg/L	BDL (DL:0.1)	0.5
21.	Anionic Detergents	Standard. Methods 23 rd Ed.5540	mg/L	BDL (DL:0.01)	0.2
22.	Sodium (as Na)	Standard. Methods 23 rd Ed.3500 Na B	mg/L	17.1	-
23.	Potassium (as K)	Standard. Methods 23 rd Ed.3500 K B	mg/L	2.0	-
24.	Coliform	IS 15185:2002	MPN/ 100ml	<1.8	Absent
25.	<i>Escherichia coli</i>	IS 15185:2002	-	Absent	Absent

BDL- Below Detectable Level

DL-Detectable Level

...End of Report...



M. Amsaveni

Authorized Signatory

(M.Amsaveni)

Technical Manager



**Greenlink Analytical and Research
Laboratory (India) Private Ltd.**

S.F. No. 414/1, Tex Park Road, Opp. Good Luck Syndicate,
Civil Aerodrome Post, Coimbatore - 641 014. Tamilnadu, INDIA.

Tel : +91 422 2901999 | Mob : +91 95245 81999, +91 95249 81999

Email : enquiry@greenlinklabs.com, info@greenlink.in



TEST REPORT

Report No.		GLARL/TRE/0398	Date	21.06.2022		
Details of Customer						
Customer Name and Address		Keystone Foundation Groves Hills Roads, BB 35, Kotagiri, Nilgiris – 643 217.				
Customer Reference						
Details of Sample						
Sample Received Date	17.06.2022		Sample-By	Greenlink		
Nature of Sample	Water-Sample 5		Description	Colorless, clear, transparent liquid.		
Sample Code	GLARL/WA/06/22/0398		Received Condition	Packed in a HDP can		
Analysis Started on	18.06.2022		Analysis Completed on	21.06.2022		
Result of Analysis						
S. No	Characteristic	Test Method		Unit	Result	Standard
1.	Colour	Standard. Methods 23 rd Ed.2120 B		Hazen	<1.0	5.0
2.	Odour	Standard. Methods 23 rd Ed.2150 B		-	Agreeable	Agreeable
3.	Taste	Standard. Methods 23 rd Ed.2160 B		-	Agreeable	Agreeable
4.	pH @ 25°C	Standard. Methods 23 rd Ed.4500 H ⁺ B		-	6.50	6.5-8.5
5.	Electrical Conductivity@ 25°C	Standard. Methods 23 rd Ed.2510 B		µS/cm	132	-
6.	Total Dissolved Solids	Standard. Methods 23 rd Ed.2540 C		mg/L	80	500
7.	Turbidity	Standard. Methods 23 rd Ed.2130 B		NTU	0.88	1.0
8.	Total Hardness (as CaCO ₃)	Standard. Methods 23 rd Ed.2340 C		mg/L	47	200
9.	Calcium (as Ca)	Standard. Methods 23 rd Ed.3500 Ca B		mg/L	12.8	75
10.	Magnesium (as Mg)	Standard. Methods 23 rd Ed.3500 Mg B		mg/L	3.65	30
11.	Total Alkalinity (as CaCO ₃)	Standard. Methods 23 rd Ed.2320 B		mg/L	38	200
12.	Chlorides (as Cl)	Standard. Methods 23 rd Ed.4500 Cl B		mg/L	19.1	250
13.	Sulphate (as SO ₄)	Standard. Methods 23 rd Ed.4500 SO ₄ E		mg/L	13.3	250

Cont.....



**Greenlink Analytical and Research
Laboratory (India) Private Ltd.**

S.F. No. 414/1, Tex Park Road, Opp. Good Luck Syndicate,
Civil Aerodrome Post, Coimbatore - 641 014. Tamilnadu, INDIA.

Tel : +91 422 2901999 | Mob : +91 95245 81999, +91 95249 81999

Email : enquiry@greenlinklabs.com, info@greenlink.in

NABL
ISO / IEC 17025
Accredited

ISO
9001 : 2015
Certified

TEST REPORT

Report No.	GLARL/TRE/0398	Date	21.06.2022
-------------------	----------------	-------------	------------

Result of Analysis					
S. No	Characteristic	Test Method	Unit	Result	Standard
14.	Silica (as SiO ₂)	Standard. Methods 23 rd Ed.4500 SiO ₂ -C	mg/L	1.771	-
15.	Total Iron (as Fe)	Standard. Methods 23 rd Ed.3500 Fe B	mg/L	0.026	0.3
16.	Nitrate (as NO ₃)	Standard. Methods 23 rd Ed.4500 NO ₂ B	mg/L	6.12	45
17.	Fluoride (as F)	Standard. Methods 23 rd Ed.4500 F-D	mg/L	0.006	1.0
18.	Total Residual Chlorine	Standard. Methods 23 rd Ed.4500 Cl(R)B	mg/L	BDL (DL:0.1)	0.2
19.	Aluminium	Standard. Methods 23 rd Ed. 3500 Al B	mg/L	BDL (DL:0.01)	0.03
20.	Ammonia	Standard. Methods 23 rd Ed.4500 NH ₃ B, C	mg/L	BDL (DL:0.1)	0.5
21.	Anionic Detergents	Standard. Methods 23 rd Ed.5540	mg/L	BDL (DL:0.01)	0.2
22.	Sodium (as Na)	Standard. Methods 23 rd Ed.3500 Na B	mg/L	20.8	-
23.	Potassium (as K)	Standard. Methods 23 rd Ed.3500 K B	mg/L	4.5	-
24.	Coliform	IS 15185:2002	MPN/ 100ml	3.6	Absent
25.	<i>Escherichia coli</i>	IS 15185:2002	-	Absent	Absent

BDL- Below Detectable Level

DL-Detectable Level

...End of Report...



M. Amsaveni
Authorized Signatory
(M.Amsaveni)
Technical Manager